

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:312 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 4100-6060 and -0160, 4020-0160 and 4120-0160 Fire Panel Internet Interfaces.
Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: Primary operating supply (all models) - 24 Vdc, 115 mA max
Output -100 Base T, Power Limited

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: The Model 4100-6060 is intended for use with the control units covered in (CSFM Listing Nos. 7170-0026:250 and 7165-0026:251). Models 4100-0160 and 4120-0160 are intended for use with the control units covered in (CSFM Listings Nos. 7165-0026:160 and 7170-0026:187). Model 4020-0160 is intended for use with the control unit covered in (CSFM Listing No. 7170-0026:178).

*Rev. 06-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager